




Novia Associates, Inc.
1 Northwestern Dr.
Salem, NH 03079
Ph: 603-898-8600
Fax: 603-898-2755
email: info@noviaassociates.com

PROJECT: _____


CUSTOMER: _____

**Ceiling Hung
Tube
Seismic
Restraint**
SD-CHT 12/05/06




Notes:

- 1) For Restraint Type EQ-9 use (4) L3 x 3 x 9"
 $\frac{1}{4}$ " Angles at connections to structure instead of
45° angle clips



* By Others

Hilti's, Nuts, Bolts,
Washers, & Beam Clamps



Type EQ-9




SEISMIC RESTRAINT TYPES

Type	Cable	Concrete Anchor	Embed. (in.)	Weld Length*
EQ-7	1/8"	3/8" HILTI	2 1/2	2
EQ-8	1/8"	5/8" HILTI	4	2
EQ-9	1/4"	(2) - 5/8" HILTI	4	2

* Weld length per angle clip are given as an optional attachment method - in lieu of concrete anchors should field conditions dictate.

EQUIPMENT TAG	Restraint type	Sets

Attachment to Structure Details



BY:

DATE:

DWG#: